

## ELECTRICAL GENERAL NOTES

1. PRODUCTS AND INSTALLATION SHALL COMPLY WITH ALL APPLICABLE LAWS, CODES, GOVERNMENT REGULATIONS, UTILITY COMPANY REQUIREMENTS, ETC. OF ALL AUTHORITIES HAVING JURISDICTION. WORK SHALL COMPLY WITH THE FOLLOWING CODES, STANDARDS AND ORGANIZATIONS:

- o 2008 NATIONAL ELECTRIC CODE
- o 2006 INTERNATIONAL BUILDING CODE
- o 2006 INTERNATIONAL MECHANICAL CODE
- o 2006 INTERNATIONAL PLUMBING CODE
- o 2006 INTERNATIONAL ENERGY CODE
- o NFPA
- o UNDERWRITERS LABORATORY (UL), IRI, FM
- o IESNA

WHERE CONFLICTS EXIST BETWEEN CODES, STANDARDS OR THIS SPECIFICATION THE HIGHER REQUIREMENT SHALL APPLY. DEVIATIONS FROM THE CONTRACT DOCUMENTS REQUIRED BY THE ABOVE AUTHORITIES SHALL BE SUBMITTED TO THE ENGINEER FOR REVIEW. OBTAIN PERMITS AND PAY ALL FEES. ARRANGE FOR ALL REQUIRED INSPECTIONS AND APPROVALS. CONFIRM ALL UTILITY COMPANY REQUIREMENTS AND CONNECTION POINTS IN FIELD, PRIOR TO STARTING WORK.

2. ALL SPECIFICATIONS AND DRAWINGS, I.E., ARCHITECTURAL, MECHANICAL, PLUMBING, AND ELECTRICAL ARE COMPLEMENTARY AND MUST BE USED IN COMBINATION TO OBTAIN COMPLETE CONSTRUCTION INFORMATION. ANY INFORMATION CONFLICTS WITH THE SPECIFICATIONS AND DRAWINGS SHALL BE BROUGHT TO THE ENGINEER'S ATTENTION. ELECTRICAL DRAWINGS ARE DIAGRAMMATIC. THEY ARE INTENDED TO SHOW THE APPROXIMATE LOCATIONS OF EQUIPMENT AND CONDUIT. THE ELECTRICAL CONTRACTOR SHALL LAYOUT ALL EQUIPMENT ROOMS TO MAKE SURE THE EQUIPMENT FITS IN THE ROOM OR SPACE SHOWN AND HAS ALL CLEARANCES REQUIRED BY THE NEC, PRIOR TO ORDER. EXACT LOCATION OF ALL EQUIPMENT SHALL BE VERIFIED IN THE FIELD AND ROUTING OF CONDUITS SHALL SUIT FIELD CONDITIONS.

3. WORK SHALL BE EXECUTED IN A GOOD WORKMANLIKE MANNER USING MECHANICS SKILLED IN THEIR RESPECTIVE TRADES. ALL EQUIPMENT AND MATERIALS SHALL BE NEW, FREE OF DEFECTS. SYSTEMS ARE TO BE COMPLETE AND WORKABLE IN ALL RESPECTS, PLACED IN OPERATION AND PROPERLY ADJUSTED.

4. MAINTAIN THE CONSTRUCTION PREMISES IN A NEAT AND ORDERLY CONDITION AT THE END OF EACH WORKING DAY. CLEAN UP, REMOVE AND LEGALLY DISPOSE OF ALL RUBBISH DAILY. CONTRACTOR SHALL PROTECT THEIR WORK AND EXISTING OR ADJACENT PROPERTY AGAINST WEATHER, TO MAINTAIN THEIR WORK, MATERIALS, APPARATUS AND FIXTURES FREE FROM INJURY OR DAMAGE. ANY WORK DAMAGED BY FAILURE TO PROVIDE PROTECTION REQUIRED, SHALL BE REMOVED AND REPLACED WITH NEW WORK AT THE CONTRACTOR'S EXPENSE.

5. THE CONTRACTOR IS SOLELY RESPONSIBLE FOR THE SAFETY OF HIS WORKERS, ALL CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES AND PROCEDURES FOR COORDINATING THE WORK UNDER THIS CONTRACT, CONFORM TO ALL GENERAL AND SPECIAL CONDITIONS OF CONTRACT AS SPECIFIED BY ARCHITECT AND/OR OWNER.

6. IN CASES OF DOUBT AS TO THE WORK INTENDED, OR IN THE EVENT OF NEED FOR EXPLANATION THEREOF, THE CONTRACTOR SHALL REQUEST SUPPLEMENTARY INSTRUCTIONS FROM THE ENGINEER. NO CHANGES ARE TO BE MADE TO THE WORK OF THIS CONTRACT WITHOUT PRIOR KNOWLEDGE AND APPROVAL OF THE ENGINEER. THE CONTRACTOR SHALL HOLD THE OWNER AND ITS CONSULTANTS HARMLESS AGAINST ALL CLAIMS AND JUDGMENTS ARISING OUT OF THE CONTRACTORS PERFORMANCE OF THE WORK OF THIS CONTRACT. THE CONTRACTOR SHALL NOT PROCEED WITH ANY WORK, WHICH HE EXPECTS ADDITIONAL COMPENSATION BEYOND THE CONTRACT AMOUNT, WITHOUT WRITTEN AUTHORIZATION FROM THE APPROPRIATE AUTHORITY. FAILURE TO OBTAIN SUCH AUTHORIZATION SHALL INVALIDATE ANY CLAIM FOR EXTRA COMPENSATION.

7. ALL PRODUCTS SHALL COMPLY WITH 25/50 FLAME AND SMOKE HAZARD RATINGS PER ASTM E-84, NFPA 255 AND UL 723.

8. IT SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR TO INSTALL ALL ELECTRICAL FIXTURES AND EQUIPMENT AS TO INSURE QUIET OPERATION. NO VIBRATION OR SOUND SHALL BE TRANSMITTED TO THE BUILDING, STRUCTURE OR OCCUPIED AREAS. THE DECISION OF THE ENGINEER AS TO THE QUIETNESS OF THE SYSTEM AND EQUIPMENT SHALL BE FINAL. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO CORRECT OR REPLACE ANY NOISY FIXTURES OR EQUIPMENT AS REQUIRED.

### BASIS OF DESIGN AND SUBSTITUTIONS

1. MANUFACTURERS LISTED ARE BASIS OF DESIGN. SUBSTITUTIONS ARE SUBJECT TO THE APPROVAL OF THE OWNER, ARCHITECT & ENGINEER. IF SUBSTITUTION IS SUBMITTED, IT IS THE CONTRACTORS RESPONSIBILITY TO EVALUATE IT AND CERTIFY THAT THE SUBSTITUTION IS EQUIVALENT IN ALL RESPECTS TO THE BASIS OF DESIGN. WHERE SUBMITTALS VARY FROM THE CONTRACT REQUIREMENTS, THE CONTRACTOR SHALL CLEARLY INDICATE ON SUBMITTAL OR ACCOMPANYING DOCUMENTS THE NATURE AND REASON FOR VARIATIONS. IF SUBSTITUTIONS ARE APPROVED, NOTIFY ALL OTHER CONTRACTORS, SUBCONTRACTORS OR TRADES AFFECTED BY SUBSTITUTION AND FULLY COORDINATE. ANY COSTS RESULTING FROM SUBSTITUTION, WHETHER BY CONTRACTOR OR OTHERS, SHALL BE RESPONSIBILITY OF AND PAID FOR BY SUBSTITUTING CONTRACTOR. APPROVED SHOP DRAWINGS DOES NOT ABSOLVE THIS CONTRACTOR FROM THIS RESPONSIBILITY. APPROVAL OF SUBSTITUTIONS IS AT THE DISCRETION OF THE ARCHITECT & ENGINEER AND IF SUBMITTED AFTER THE BID, AT THE RISK OF THE CONTRACTOR.

### SHOP DRAWING SUBMITTALS

1. COORDINATE, PREPARE AND SUBMIT SHOP DRAWINGS TO THE ARCHITECT AND ENGINEER FOR THEIR REVIEW. CONTRACTOR SHALL REVIEW AND INDICATE HIS APPROVAL OF EACH SHOP DRAWING PRIOR TO SUBMITTAL FOR REVIEW. DO NOT ORDER, START WORK OR FABRICATION UNTIL SHOP DRAWINGS HAVE BEEN REVIEWED BY THE ENGINEER AND RETURNED TO THE CONTRACTOR. SHOP DRAWINGS TO BE SUBMITTED INCLUDE, BUT NOT LIMITED TO:

- o WIRING DEVICES
- o PANEL, BOARDS, STARTERS, SAFETY SWITCHES, TRANSFORMERS
- o CONNECTORS
- o LIGHTING SYSTEMS, FIXTURES AND EQUIPMENT
- o UNDERGROUND CONDUIT COORDINATION DRAWING SHOWING ACTUAL ROUTING AND BURIAL DEPTH COORDINATED WITH ALL OTHER EXISTING AND NEW UNDERGROUND PIPING AND CONDUIT.

2. CLEARLY IDENTIFY EACH ITEM ON THE SUBMITTAL AS TO MARK, LOCATION AND USE, USING SAME IDENTIFICATION AS PROVIDED ON DESIGN DRAWINGS. ELECTRONIC SUBMITTALS SHALL BE PRESENTED WITH ALL SHEETS IN ALPHANUMERIC ORDER AND ALL SHEETS ORIENTED WITH TOP OF SHEET UP.

3. SUBMITTALS WILL BE REVIEWED ONLY FOR GENERAL COMPLIANCE WITH THE CONTRACT DOCUMENTS AND NOT FOR DIMENSIONS OR QUANTITIES. THE SUBMITTAL REVIEW SHALL NOT RELIEVE THE CONTRACTOR OF RESPONSIBILITY FOR PURCHASE OF ANY ITEM IN FULL COMPLIANCE WITH THE CONTRACT DOCUMENTS OR ITS COMPLETE AND PROPER INSTALLATION.

### RECORD DRAWINGS

1. A SET OF MEP RECORD/COORDINATION DRAWINGS SHALL BE MAINTAINED IN THE GENERAL CONTRACTORS OFFICE AT THE JOB SITE. PRINTS SHALL INDICATE ADDITIONS, DELETIONS, VARIATIONS IN LOCATION, VARIATIONS IN NUMBERING ETC. ALTERATIONS SHALL BE MARKED IN RED AND DELETIONS ALL BE MARKED IN GREEN AND SHALL BE ON THE LATEST CONTRACT DRAWING ISSUED. RECORD DRAWINGS SHALL BE KEPT CLEAN AND UNDAIMAGED AND SHALL NOT BE USED FOR ANY PURPOSE OTHER THAN RECORDING DEVIATIONS FROM WORKING DRAWINGS. AFTER THE PROJECT IS COMPLETED, THESE SETS OF DRAWINGS SHALL BE DELIVERED TO THE ARCHITECT IN GOOD CONDITION, AS A PERMANENT RECORD OF THE INSTALLATION AS ACTUALLY CONSTRUCTED.

### EQUIPMENT

1. ALL PACKAGED EQUIPMENT SHALL BE INDEPENDENTLY THIRD PARTY LABELED AS A SYSTEM FOR ITS INTENDED USE BY A NATIONALLY RECOGNIZED TESTING LABORATORY (NRTL) IN ACCORDANCE WITH OSHA FEDERAL REGULATIONS 29CFR1910.303 AND .399, AS WELL AS NFPA PAMPHLET NO. 70, AND THE NATIONAL ELECTRICAL CODE (NEC), ARTICLE 30-7.

2. MAKE ALL FINAL EQUIPMENT CONNECTIONS AND PROVIDE THE NECESSARY ADAPTORS, FITTINGS, DEVICES, ETC. FOR A COMPLETE AND OPERABLE SYSTEM. PROVIDE COMPLETE WITH BASES, ISOLATORS, SUPPORTS AND OTHER REQUIRED ACCESSORIES.

3. EQUIPMENT SHALL BE INSTALLED IN FULL ACCORDANCE WITH THE MANUFACTURER'S DATA AND INSTALLATION INSTRUCTIONS, INCLUDING CLEARANCES. IT IS THIS CONTRACTOR'S RESPONSIBILITY TO CHECK AND CONFORM TO THESE REQUIREMENTS PRIOR TO STARTING WORK.

4. THE CONTRACTOR SHALL COORDINATE WITH THE OTHER TRADES FOR ELECTRICAL CHARACTERISTICS OF ALL EQUIPMENT. COORDINATE REQUIREMENT FOR PROVISION OF MOTOR STARTERS, DISCONNECTS, CONTACTORS, CONTROL WIRING, ETC. AS REQUIRED FOR PROPER FUNCTIONING SYSTEM.

5. ALL FLOOR MOUNTED EQUIPMENT SHALL BE INSTALLED ON CONCRETE HOUSEKEEPING PADS. MINIMUM PAD THICKNESS SHALL BE NOMINAL 4". PAD SHALL EXTEND BEYOND THE EQUIPMENT A MINIMUM OF 4" ON EACH SIDE. CONCRETE PADS SHALL BE PROVIDED BY THIS CONTRACTOR. IT SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR TO COORDINATE THE SIZE AND LOCATION OF THE CONCRETE HOUSEKEEPING PADS WITH THE GENERAL CONTRACTOR.

### IDENTIFICATION

1. FURNISH AND MOUNT ON EACH PANELBOARD, SWITCHBOARD (INCLUDING BRANCH SWITCHES), LARGE JUNCTION BOX, SAFETY SWITCH, STARTER, REMOTE CONTROL, PUSH BUTTON STATION, AND ALL SIMILAR CONTROLS, A NAMEPLATE DESCRIPTIVE OF THE EQUIPMENT OR EQUIPMENT CONTROLLED.

2. WRITE BLACK AND WHITE NAMEPLATES CONSTRUCTED FROM LAMINATED PHENOLIC WITH A WHITE CENTER CORE. LETTERS SHALL BE ENGRAVED IN THE PHENOLIC TO FORM WHITE LETTERS 3/8" HIGH.

### CUTTING, PATCHING AND DRILLING

1. ALL CUTTING AND PATCHING OF THE BUILDING CONSTRUCTION REQUIRED FOR THIS WORK SHALL BE BY THIS CONTRACTOR UNLESS SHOWN ON ARCHITECTURAL DRAWINGS AND CONFIRMED AS TO SIZE AND LOCATION PRIOR TO NEW CONSTRUCTION. CUTTING SHALL BE IN A NEAT AND WORKMANLIKE MANNER.

2. DO NOT CORE DRILL OR CUT ANY CONCRETE SLABS OR OTHER STRUCTURAL COMPONENTS FOR ANY REASON WITHOUT THE KNOWLEDGE AND WRITTEN CONSENT OF THE STRUCTURAL ENGINEER, ARCHITECT AND THE OWNER.

3. PATCH AND FINISH TO MATCH ADJACENT AREAS THAT HAVE BEEN CUT, DAMAGED OR MODIFIED AS A RESULT OF THE INSTALLATION OF THE MECHANICAL OR ELECTRICAL EQUIPMENT.

### MOUNTING ACCESSORIES

1. THIS CONTRACTOR SHALL FURNISH AND INSTALL ALL ANGLE IRON, CHANNEL IRON, RODS, SUPPORTS, HANGERS, CONCRETE OR PLYWOOD REQUIRED TO INSTALL, MOUNT AND SUPPORT ANY ELECTRICAL EQUIPMENT OR DEVICE CALLED FOR ON THE PLANS.

2. SUPPORTING MATERIAL SHALL BE COMPLETE WITH HANGERS, CONNECTORS, BOLTS, CLAMPS AND NECESSARY ACCESSORIES TO MAKE A COMPLETE INSTALLATION. SUPPORTING MATERIAL SHALL BE GALVANIZED, PAINTED OR OTHERWISE SUITABLY FINISHED.

### FIRESTOPPING/FIRE DAMPERS

1. ALL PENETRATIONS OF SLAB-TO-SLAB PARTITIONS SHALL BE SEALED AIRTIGHT.

2. WHEREVER FIRE RATED PARTITIONS ARE PENETRATED FOR WIRE, DUCT, OR PIPE PASSAGE, SEAL PASSAGES WITH CODE APPROVED, LABORATORY TESTED AND LABELED SEALANT OF FIRE RESISTANCE RATING NOT LESS THAN THAT OF PENETRATED ASSEMBLY THAT WILL PREVENT PASSAGE OF FIRE AND SMOKE. ALL FIRE STOPPING SYSTEM SHALL MEET THE REQUIREMENTS OF ASTM E 814UL 1479, AND BE FACTORY MUTUAL APPROVED. ALL FIRESTOPPING AND/OR SMOKE STOPPING MATERIAL AND INSTALLATION SHALL BE AS MANUFACTURED BY HILTI OR APPROVED EQUAL.

3. INSTALLATION OF LIGHT FIXTURES, AND OUTLETS IN RATED CEILINGSS OR WALLS SHALL HAVE RATED BOXES OR BE PROVIDED WITH PREMANUFACTURED TENTS MATCHING THE RATING OF THE CEILING OR WALL ASSEMBLY.

### ACCESS DOORS

1. ACCESS DOORS SHALL BE PROVIDED IN WALLS AND CEILINGSS WHERE REQUIRED TO PERMIT PROPER ACCESS TO EQUIPMENT AND OTHER DEVICES WHICH REQUIRE MAINTENANCE OR SERVICE. DOORS PLACED IN WALLS, PARTITIONS OR OTHER FIRE-RATED CONSTRUCTION SHALL HAVE A LABEL SIGNIFYING THAT THE DOOR HAS THE SAME FIRE RATING AS THE FIRE-RATED CONSTRUCTION.

2. ACCESS PANELS SHALL BE CONSTRUCTED OF 14 GAUGE STEEL, WITH 16 GAUGE STEEL FRAMES. DOORS SHALL FINISH FLUSH WITH THE SURROUNDING SURFACE. FRAMES SHALL HAVE 3" WIDE EXPANDED METAL FOR PLASTERED SURFACES AND PLAIN FLANGED TYPE FRAME FOR TILE, MASONRY OR GYPSUM BOARD SURFACES. DOORS AND FRAMES SHALL BE FURNISHED PRIME COATED. DOORS INSTALLED IN CERAMIC TILE OR OTHER NON-PAINTED SURFACES SHALL BE STAINLESS STEEL. HINGES SHALL BE CONCEALED SPRING TYPE, TO ALLOW DOORS TO BE OPENED 75 DEGREES. LOCKS SHALL BE FLUSH SCREWDRIVER TYPE WITH STEEL CAMS. ACCESS PANELS SHALL BE 16" X 16" OR LARGER AS MAY BE REQUIRED FOR PROPER ACCESS TO THE DEVICE BEING SERVED.

3. ACCESS PANELS ARE NOT REQUIRED IN COMPLETELY ACCESSIBLE LIFT OUT TILE CEILINGSS. CONTRACTOR SHALL REVIEW THE ROOM FINISH SCHEDULE ON THE ARCHITECTURAL DRAWINGS IN ORDER TO VERIFY THE NEED FOR ACCESS PANELS. PROVIDE ACCESS PANELS TO GENERAL CONTRACTOR FOR INSTALLATION.

### RACEWAYS

1. ALL WIRE SHALL BE RUN IN ACCORDANCE WITH CODE IN INTERMEDIATE METAL CONDUIT (IMC) OR ELECTRICAL METALLIC TUBING (EMT) OR METAL CLAD (MC) CABLING UNLESS OTHERWISE SPECIFICALLY STATED HEREIN. CONDUIT SIZE SHALL BE 3/4" MINIMUM UNLESS NOTED OTHERWISE.

2. CONDUIT IN EXTERIOR WALLS, EXPOSED TO THE WEATHER OR OTHER DAMP/WET LOCATIONS SHALL BE RIGID, THREADED, GALVANIZED, HEAVY WALL TYPE.

3. CONDUIT UNDERGROUND SHALL BE SCHEDULE 40 PVC CONDUIT WITH GROUND WIRE. PVC CONDUIT SHALL NOT BE RUN IN OR ABOVE FLOOR SLAB. PVC CONDUIT SHALL TERMINATE BELOW FLOOR SLAB WITH RIGID, THREADED METAL CONDUIT ADAPTER. CONDUIT ABOVE SLAB SHALL BE METAL.

4. ALL CONDUIT SHALL BE CONCEALED IN WALLS, FLOORS AND CEILINGSS WHEREVER POSSIBLE. EXPOSED CONDUIT IN FINISHED AREAS WILL NOT BE PERMITTED. EXPOSED CONDUIT WILL BE PERMITTED IN UNFINISHED AREAS WITH THE SPECIFIC APPROVAL OF THE ARCHITECT.

5. USE FLEXIBLE CONDUIT FOR THE CONNECTION TO THE RECESSED OR SEMI-RECESSED LIGHTING FIXTURES (6" LENGTH MAXIMUM). USE LIQUID TIGHT METAL CONDUIT FOR ALL CONNECTIONS TO MOTORS AND OTHER EQUIPMENT SUBJECT TO VIBRATION AND IN AREAS SUBJECT TO MOISTURE.

6. USE WATERTIGHT JOINTS WITH BURIED AND CONCRETE ENCASED CONDUIT. ALL BURIED CONDUITS OUTSIDE OF BUILDINGS SHALL HAVE A MINIMUM OF 24" OF COVER. METAL CONDUITS BURIED IN EARTH SHALL BE PAINTED WITH TWO COATS OF HEAVY ASPHALTUM PAINT.

7. CONDUIT SHALL BE SECURELY FASTENED IN PLACE. SUPPORT RUNS OF CONDUIT AS DETAILED IN THE APPROPRIATE TABLE OF THE NATIONAL ELECTRICAL CODE.

8. INSTALL EXPOSED RUNS OF CONDUIT AND CONDUIT ABOVE LAY-IN CEILINGSS PARALLEL OR PERPENDICULAR TO THE WALLS, STRUCTURAL MEMBERS OF INTERSECTIONS OF VERTICAL PLANS AND CEILINGSS. PROVIDE RIGHT ANGLE TURNS USING FITTINGS OR SYMMETRICAL BENDS. SUPPORT CONDUITS WITHIN 1' OF ALL CHANGES IN DIRECTION.

9. IF A CONDUIT IS SUSPENDED, IT SHALL BE SUPPORTED ON TRAPEZE HANGERS, WHICH USE 'ALL-THREAD' RODS FROM THE STRUCTURAL STEEL. THE USE OF CEILING SUPPORT WIRE OR SIMILAR MATERIAL WILL NOT BE ACCEPTED.

10. INSTALL EMPTY CONDUIT FOR FUTURE USE AS INDICATED ON THE DRAWINGS. CONDUIT SHALL BE COMPLETE WITH JETLINE OR PULL ROPE, JUNCTION/OUTLET BOXES, TILE RINGS AND APPROPRIATE COVER PLATES.

11. PROVIDE PITCH-POCKETS WHERE CONDUITS PENETRATE THE ROOF. HORIZONTAL PORTIONS OF CONDUIT EXPOSED ON THE ROOF AND FEEDING EQUIPMENT SHALL NOT BE MORE THAN 5'-0" UNLESS THE WRITTEN APPROVAL FROM ARCHITECT OR ENGINEER IS OBTAINED.

12. THREAD LUBRICATION/SEALANT IS REQUIRED ON OUTDOOR AND UNDERGROUND THREADED METAL JOINTS.

13. COORDINATE CONDUIT RUNS WITH OTHER TRADES AND ADJUST ROUTING TO AVOID INTERFERENCE.

14. RACEWAYS SHALL BE PROVIDED WITH EXPANSION FITTINGS WHERE NECESSARY TO COMPENSATE FOR THERMAL EXPANSION AND CONTRACTION.

15. SURFACE RACEWAYS SHALL BE AS INDICATED ON DRAWINGS AND INSTALLED AS A COMPLETE SYSTEM WITH ALL REQUIRED FITTINGS AND APPURTENANCES. RECEPTACLES/OUTLETS AS INDICATED ON PLAN, INSTALL RACEWAYS PARALLEL AND PERPENDICULAR TO BUILDING ELEMENTS.

### BOXES

1. INSTALL PULL AND JUNCTION BOXES WHERE SHOWN ON THE DRAWINGS, AND WHERE REQUIRED FOR CHANGES IN DIRECTION, AT JUNCTION POINTS AND TO FACILITATE WIRE PULLING. FURNISH BOX SIZES IN ACCORDANCE WITH NEC UNLESS LARGER BOXES ARE INDICATED ON THE DRAWINGS.

2. INTERIOR CONCEALED - USE SHEET STEEL BOXES, ZINC COATED OR CADMIUM PLATED

3. IN FLOOR LOCATIONS - PROVIDE CAST IRON, CONCRETE-TITE FLOOR BOXES WITH ADJUSTABLE COVERS SET FLUSH AND LEVEL WITH THE FINISHED FLOOR, WITH OUTLETS AS INDICATED ON THE DRAWINGS. PROVIDE BOXES WITH LEVELING SCREWS. FLUSH TYPE BRASS COVERS AND OPENINGS TO SERVE OUTLETS USED. FURNISH FLUSH CAPS FOR CLOSING OFF BOX WHEN NOT IN USE.

4. ALL OTHER LOCATIONS EXCEPT BELOW GRADE - USE CAST BOXES, ZINC-CADMIUM FINISH MALLEABLE IRON. FURNISH WEATHERPROOF BOXES WHEN INSTALLED OUTSIDE OR IN DAMP/WET LOCATIONS.

5. PROVIDE REMOVABLE COVERS OF CODE GAUGE, HOT ROLLED SHEET STEEL, HOT DIPPED GALVANIZED FOR ALL BOXES, UNO.

6. EXTERIOR BELOW GRADE - COMPOSITE WATERPROOF ASSEMBLIES SUITABLE FOR INGROUND INSTALLATIONS.

7. WALL BOX SIZES SHALL BE MINIMUM 4" SQUARE X 2-1/2" DEEP WHERE WALL CONSTRUCTION PERMITS. FIXTURE OUTLETS IN CEILING SHALL BE MINIMUM 4" OCTAGONAL X 1-1/2" DEEP (4-1/16" OCTAGONAL X 2-1/2" DEEP WHERE REQUIRED TO ACCOMMODATE LARGER CONDUIT OR LARGER NUMBER OF WIRES). GANG BOXES SHALL BE ONE PIECE MINIMUM 2-1/8" DEEP.

8. FLUSH MOUNT BOXES IN ALL FINISHED WALLS, INSTALL THE PLASTER RINGS IN DRYWALLED PLASTERED WALLS AND RAISED COVERS AS REQUIRED IN WALLS WITH OTHER FINISHES SO THAT THE COVER PLATES FIT TIGHTLY AGAINST BOXES OR RINGS. 3/16" MAXIMUM GAPS ARE ALLOWED FOR NONCOMBUSTIBLE WALLS. SUPPORT ALL BOXES TO MAINTAIN PROPER ALIGNMENT AND RIGIDITY. CLEAN BOXES OF ALL FOREIGN MATTER PRIOR TO THE INSTALLATION OR WIRING OR DEVICES.

9. MOUNTING HEIGHTS ON THE DRAWING ARE TO THE CENTERLINE OF THE BOXES UNLESS OTHERWISE NOTED. ADJUST LOCATIONS OF OUTLETS IN MASONRY OR TILE CONSTRUCTION TO OCCUR IN THE NEAREST JOINT TO THE HEIGHT SPECIFIED. HEIGHTS SHALL MEET ADA REQUIREMENTS.

### CONDUCTORS

1. COLOR CODE CONDUCTORS (EXCEPT CONTROL AND INSTRUMENTATION CONDUCTORS) AS FOLLOWS:

	208/120 VOLT SYSTEM
PHASE A	BLACK
PHASE B	RED
PHASE C	BLUE
NEUTRAL	WHITE
GROUND	GREEN

- o #12 AND #10 CONDUCTORS SHALL HAVE CONTINUOUS INSULATION COLOR, AS LISTED ABOVE.
- o COLOR CODE CONDUCTORS LARGER THAN ABOVE, WHICH DO NOT HAVE CONTINUOUS INSULATION COLOR BY APPLICATION OF AT LEAST TWO LAPS OF COLORED TAPE ON EACH CONDUCTOR AT ALL POINTS OF ACCESS INCLUDING JUNCTION BOXES.
- o CONDUCTORS SHALL BE SOFT ANNEALED COPPER INSULATED FOR 600 VOLTS UNLESS SPECIFICALLY INDICATED OTHERWISE.
- o DRAWINGS INDICATE SIZES BASED ON COPPER CONDUCTORS.

2. INSULATION TYPE SHALL BE TYPE THW FOR WIRE SIZES #8 AWG AND LARGER AND THWN FOR #10 AWG AND SMALLER. THIN SHALL NOT BE USED IN WET OR DAMP LOCATIONS.

3. FLEXIBLE CORD SHALL BE HEAVY DUTY TYPE 60 WITH AN EQUIPMENT GROUND CONDUCTOR IN ADDITION TO THE CURRENT CARRYING CONDUCTORS.

4. PROVIDE #12 CONDUCTORS, UNLESS OTHERWISE INDICATED. CONTROL CONDUCTORS SHALL BE #14 MINIMUM FOR NEC CLASS 1 AND #16 FOR NEC CLASS 11. CONDUCTORS #8 AWG AND LARGER SHALL BE STRANDED. CONDUCTORS #10 AWG AND SMALLER SHALL BE SOLID.

5. CONNECT #10 AND SMALLER WIRES WITH CONSTANT PRESSURE EXPANDABLE SPRING TYPE CONNECTORS. CONNECT #8 AND LARGER WIRES WITH COMPRESSION CONNECTORS OR SPLICES.

6. INSTALL WIRING IN CONDUIT. PULL CONDUCTORS USING RECOGNIZED METHODS AND EQUIPMENT LEAVING AT LEAST 6" WIRE AT ALL JUNCTION BOXES FOR CONNECTIONS. CLEANOUT EACH CONDUIT SYSTEM TO ELIMINATE OBSTRUCTIONS OVER FULL LENGTH BEFORE PULLING WIRE.

7. FORM AND TIE ALL WIRING IN PANELBOARDS. THERE SHALL BE NO WIRENUT JOINTS OR SPLICES MADE INSIDE SWITCHES/PANELBOARDS.

8. BRANCH CIRCUIT WIRE SIZES (AND CONDUITS) SHALL BE INCREASED FROM THOSE INDICATED ON THE PLANS TO PREVENT EXCESSIVE VOLTAGE DROP. BRANCH CIRCUITS SHALL BE INSTALLED WITH WIRES OF SUFFICIENT SIZE SO THAT VOLTAGE DROP BETWEEN THE PANEL AND THE LOADS DOES NOT EXCEED LIMIT OF 2%.

9. WIRE SIZES SHALL BE BASED ON THE 60°C, AMPACITIES FOR WIRE SIZES #14-1 AWG AND 75°C AMPACITIES FOR WIRE SIZES #10 AWG AND LARGER.

10. CIRCUITS MAY BE MULTI-PLEXED IN CONDUIT PROVIDED WIRE IS PROPERLY DERATED AND CONDUIT SIZED PER NEC. UNDER NO CIRCUMSTANCES SHALL MORE THAN NINE (9) CURRENT CARRYING CONDUCTORS BE RUN IN A SINGLE CONDUIT. WIREMOLD SERVED BY MULTIPLE CIRCUITS SHALL BE WIRED WITH INDIVIDUAL SEPARATE NEUTRALS FOR EACH CIRCUIT.

11. METAL-CLAD (MC) OR ARMORED CABLE (AC) MAY BE USED FOR BRANCH CIRCUITS WHERE ALLOWED BY CODE. ARMORED CABLE SHALL NOT BE USED IN ASSEMBLY AREAS OR WHERE PROHIBITED BY CODE. CABLES SHALL BE CONCEALED IN FINISHED SPACES. TEST CABLES FOR CONTINUITY AND GROUNDS. INSTALL CABLES PARALLEL AND PERPENDICULAR TO BUILDING SURFACES. COORDINATE CABLE RUNS WITH OTHER TRADES AND ADJUST ROUTING TO AVOID INTERFERENCE. LOW VOLTAGE WIRING INSTALLED ABOVE CEILINGSS SHALL BE BUNDLED AND SUPPORTED FROM THE BUILDING STRUCTURE. DO NOT LAY CABLE ON CEILINGSS.

### DEVICES

1. WIRING DEVICE COLOR SHALL BE IVORY OR AS SELECTED BY ARCHITECT, UNLESS OTHERWISE INDICATED.

2. PROVIDE TOTALLY ENCLOSED, SPECIFICATION GRADE, 20 AMPERE, 120/277 VOLT QUIET A/C GENERAL USE SNAP SWITCHES MANUFACTURED BY HUBBELL, P&S OR LEVITON.

3. PROVIDE SPECIFICATION GRADE NEMA CONFIGURATION S-20R DUPLEX 125-VOLT GROUNDING TYPE RECEPTACLES UNLESS OTHERWISE NOTED ON THE DRAWINGS. MANUFACTURED BY HUBBELL, P&S OR LEVITON.

4. RECEPTACLES REQUIRING AMPERAGES, VOLTAGES OR CONFIGURATIONS DIFFERENT FROM THE DUPLEX CONVENIENCE RECEPTACLES ABOVE SHALL BE AS INDICATED ON THE DRAWINGS AND OF A QUALITY, MATERIAL AND CONSTRUCTION EQUAL TO THAT SPECIFIED FOR DUPLEX CONVENIENCE RECEPTACLES.

5. PROVIDE COVER OR DEVICE PLATES FOR OUTLET BOXES AS FOLLOWS UNLESS OTHERWISE NOTED:

- o FINISHED AREAS: THERMOPLASTIC-COLOR TO MATCH DEVICE
- o UNFINISHED AREAS: ZINC COATED SHEET METAL, ALUMINUM, OR CAST METAL AS APPROPRIATE FOR THE TYPE OF BOX.
- o EXTERIOR AREAS: COPPER FREE ALUMINUM WITH GRAY, POWDER EPOXY FINISH, GASKETED, WEATHERPROOF.
- o ALL OUTLET AND/OR JUNCTION BOXES SHALL BE COMPLETE WITH A COVER PLATE BY THIS CONTRACTOR. WHERE DEVICES ARE GANGED, THEY SHALL BE INSTALLED UNDER A COMMON COVER-PLATE.
- o LOCATE THE SWITCHES APPROXIMATELY 4'-0" ABOVE THE FINISHED FLOOR ELEVATION OR NEAREST BLOCK COURSE (WITH IN ADA REQUIREMENTS) UNLESS OTHERWISE NOTED. THE LONG DIMENSION OF THE SWITCHES SHALL BE VERTICAL.

6. LOCATE RECEPTACLES APPROXIMATELY 1'-6" ABOVE THE FINISHED FLOOR ELEVATION OR NEAREST BLOCK COURSE (WITH IN ADA REQUIREMENTS), UNLESS OTHERWISE NOTED. THE LONG DIMENSION OF THE RECEPTACLE SHALL BE VERTICAL. ALL DEVICES SHALL BE FLUSH MOUNTED U.N.O.

7. RECEPTACLES WITHIN 6' OF SINKS SHALL BE GFCI TYPE. ALL DEVICES INSTALLED OUTDOORS SHALL BE WEATHERPROOF AND GFCI PROTECTED.

8. RECEPTACLE IN KITCHEN AREA OR BATHROOM TO BE GFCI PROTECTED.

### SAFETY SWITCHES

1. PROVIDE DISCONNECT SWITCHES FOR ALL EQUIPMENT, WHERE REQUIRED BY CODE. MANUFACTURER SHALL BE SQUARE D, SIEMENS, G.E., OR CUTLER-HAMMER. ALL SAFETY SWITCHES SHALL BE BY ONE MANUFACTURER.

2. SAFETY SWITCHES SHALL BE THE ENCLOSED HEAVY-DUTY TYPE (TYPE HD) WITH QUICK-MAKE, QUICK-BREAK MECHANISM AND EXTERNAL PAD LOCKABLE OPERATING HANDLE.

3. SAFETY SWITCHES SHALL BE RATED FOR 340 OR 600 VOLTS AS APPLICABLE. THEY SHALL BE HORSEPOWER RATED WHEN USED IN MOTOR CIRCUITS. SAFETY SWITCHES SHALL BE FUSIBLE OR NONFUSIBLE 2, 3 OR 4 POLE AS INDICATED ON THE DRAWINGS. SAFETY SWITCHES SHALL BE SINGLE THROW, UNO. ENCLOSURES SHALL BE NEMA 1 INDOORS AND NEMA 3R OUTDOORS UNLESS OTHERWISE INDICATED ON THE DRAWINGS.

4. MOUNT THE SAFETY SWITCHES SECURELY BETWEEN 3' X 6' LEVELS ABOVE THE FLOOR UNLESS OTHERWISE NOTED IN THE DRAWINGS. SWITCHES ON BLOCK WALLS SHALL BE MOUNTED ON A 3/4" PLYWOOD BACKBOARD, WHERE LOCATED INDOORS.

5. THE CONTRACTOR SHALL FURNISH A COMPLETE SET OF FUSES FOR ALL FUSIBLE SWITCHES, PLUS FUSIBLE EQUIPMENT FURNISHED BY OTHER TRADES. UNLESS OTHERWISE INDICATED ON THE DRAWINGS, THE FUSES SHALL BE OF THE FOLLOWING TYPE:

- o FUSES 601 TO 6000 AMPS SHALL BE UL CLASS RK5. TRADE TYPE SHALL BE KRP-C AS MANUFACTURED BY THE BUSBMANN COMPANY.
- o FUSES 1/10 TO 600 AMPS SHALL BE UL CLASS RK1. TRADE TYPE SHALL BE LOW PEAK LPS-RK (600V) AND LPN-RK (250C) AS MANUFACTURED BY BUSBMANN COMPANY.
- o ALL OTHER FUSES SHALL BE DUAL ELEMENT CURRENT LIMITING TYPE WITH 200,000 AMPERES SYMMETRICAL INTERRUPTING CAPACITY.

6. THIS CONTRACTOR SHALL REPLACE ALL FUSES BLOWN DURING CONSTRUCTION.

### MOTOR STARTERS

1. STARTERS SHALL BE SQUARE D, G.E., CUTLER-HAMMER/WESTINGHOUSE, OR SIEMENS.

2. COORDINATE ALL EQUIPMENT INDICATED ON THE ELECTRICAL DRAWINGS WITH MECHANICAL EQUIPMENT SCHEDULES AND SPECIFICATIONS. STARTERS AND DISCONNECTS SUPPLIED AS AN INTEGRAL PART OF EQUIPMENT SHALL BE FURNISHED UNDER THE DIVISION PROVIDING THE EQUIPMENT. WIRING AND EQUIPMENT CONNECTIONS SHALL BE BY THIS CONTRACTOR.

### DISTRIBUTION PANELS

1. DISTRIBUTION PANELS SHALL BE DEAD FRONT TYPE WITH CIRCUIT BREAKERS, FUSES AND HEAVY-DUTY SWITCHES OF SIZE AND NUMBER INDICATED ON THE PANELS. PANELS SHALL BE MANUFACTURED AS A COMPLETE UNIT AND NOT AN ASSEMBLY OF PARTS SECURED FROM A SUPPLY HOUSE. ALL BUS BARS SHALL BE RECTANGULAR SOLID COPPER. ALL LUGS SHALL BE UL APPROVED C/U/L TYPE. VERTICAL BUSBING SHALL BE EXTENDED THE FULL LENGTH OF THE PANEL. ALL PANELS SHALL BE CAPABLE OF ACCEPTING SWITCH SIZES UP TO AND INCLUDING 600 AMPS. DISTRIBUTION PANELS SHALL BE G.E., SQUARE 'D', SIEMENS, OR WESTINGHOUSE.

2. THE INDIVIDUAL SWITCH AND FUSE UNITS SHALL BE OF THE QUICK-MAKE, QUICK-BREAK TYPE. FUSED UNITS SHALL HAVE HINGED FUSE COMPARTMENTS WITH INTERLOCKED FUSE DOORS WHEN THE EXTERNALLY OPERATED HANDLE IS IN THE OFF POSITION. THESE UNITS SHALL BE REMOVABLE AND ACCESSIBLE FROM THE FRONT SO THAT THE CABINET MAY BE WALL-MOUNTED.

3. INSTALL PANELS SUCH THAT HANDLE FOR THE TOP SWITCH DOES NOT EXCEED 6'-6" ABOVE FINISHED FLOOR. SURFACE-MOUNTED PANELS SHALL BE MOUNTED ON A 3/4" PLYWOOD BACKBOARD. FLOOR-MOUNTED PANELS SHALL BE MOUNTED ON A 4" HIGH CONCRETE PAD. PROVIDE PHENOLIC LABELS FOR EACH PANEL AND FOR EACH SWITCH.

4. ALL BOLTED CONNECTIONS SHALL BE TORQUED IN ACCORDANCE WITH MANUFACTURERS STANDARDS. RETORQUE CONNECTIONS ONE MONTH OR MORE AFTER INITIAL TORQUE.

### PANELBOARDS

1. PANELBOARDS SHALL BE ENCLOSED DEAD FRONT SAFETY TYPE WITH FEATURES AND RATINGS AS SCHEDULED ON DRAWINGS. ALL BUS BARS SHALL BE RECTANGULAR SOLID COPPER. SPACE, WHERE SHOWN IN PANEL SCHEDULES, DESIGNATES SPACE FOR FUTURE PROTECTIVE DEVICES AND SHALL INCLUDE BUS AND SUPPORT. PANELS KNOWN AS 'LOAD CENTERS' ARE UNACCEPTABLE. MANUFACTURER SHALL BE SQUARE D, SIEMENS, GE OR CUTLER-HAMMER.

2. MOLDED CASE CIRCUIT BREAKERS SHALL BE AS SCHEDULED ON THE DRAWINGS AND SPECIFIED IN THIS DIVISION. ALL BREAKERS SHALL BE BOLT ON TYPE. ALL BOLTED CONNECTIONS SHALL BE TORQUED IN ACCORDANCE WITH MANUFACTURERS STANDARDS. RETORQUE ALL CONNECTIONS ONE MONTH AFTER INITIAL TORQUE.

3. INSTALL CABINETS SO THAT CENTER OF THE TOP BREAKER DOES NOT EXCEED 6'-6" ABOVE THE FINISHED FLOOR. PROVIDE (3) SPARE 1" CONDUITS INTO ACCESSIBLE CEILING WHERE PANELS ARE FLUSH MOUNTED.

4. ELECTRICAL CONTRACTOR SHALL ARRANGE CIRCUITS AS NEAR AS POSSIBLE TO CIRCUIT NUMBERS ON THE DRAWINGS. AT COMPLETION OF JOB, ELECTRICAL CONTRACTOR SHALL TAKE CURRENT READING CHECKS OF RESPECTIVE PHASES. A MINIMUM OF CIRCUIT CONNECTIONS SHALL BE REARRANGED TO BALANCE, AS CLOSELY AS POSSIBLE, THE LOAD IN THE PANEL. ENTRIES ON DIRECTORY CARDS SHALL BE TYPED, COMPLETE AND ACCURATE. FINAL ROOM NAMES/NUMBERS MAY BE DIFFERENT FROM THOSE USED ON PLANS AND SHOULD BE USED TO CREATE DIRECTORIES.

### GROUNDING

1. GROUND ALL EQUIPMENT PER NEC. GROUND EACH OUTSIDE LIGHTING STANDARD SEPARATELY WITH ONE GROUND ROD AND A #6 GROUND WIRE.

2. ALL CONDUITS SHALL CONTAIN A CODE SIZED GROUND WIRE SIZE PER NEC IN ADDITION TO THE CONDUCTORS SHOWN ON THE PLANS. WHERE CIRCUIT CONDUCTORS ARE INCREASED IN SIZE THE GROUND WIRE SIZE SHALL BE INCREASED PROPORTIONALLY.

3. WHERE AN ISOLATED, INSULATED GROUND IS REQUIRED A SEPARATE GREEN GROUND SHALL BE RUN FROM THE PANEL GROUND BUS TO THE ISOLATED GROUND CONNECTION OF THE DEVICE SERVED. IN NO CASE SHALL THE SYSTEM GROUND (WIRE AND ASSOCIATED OUTLET BOXES, CONDUIT AND BUILDING STEEL) BE ALLOWED TO CONTACT THE ISOLATED GROUND (GREEN WIRE AND DEVICE GROUND).

### COMMUNICATION SYSTEMS

1. PROVIDE A 3/4" THICK PLYWOOD TERMINAL BOARD AS SHOWN ON DRAWINGS. ELECTRICAL CONTRACTOR TO PROVIDE TELEPHONE SERVICE CONDUIT OR DUCT TO TELEPHONE BOARD AS SHOWN ON PLANS. CONDUIT TO BE A MINIMUM OF 3/4".

2. THIS CONTRACTOR SHALL PROVIDE AND INSTALL ALL CONDUITS WITH PULL WIRES, OUTLET BOXES, METAL CABINETS AND PULL BOXES. PROVIDE A COMPLETE CONDUIT SYSTEM WITH PULL WIRES AS INDICATED ON THE DRAWINGS. ALL CONDUIT RUN SHALL HAVE NOT MORE THAN THREE (3) BENDS IN A RUN BETWEEN OUTLET BOXES OR BETWEEN OUTLET BOX AND A METAL CABINET OR PULL BOX. WHEN A RUN REQUIRES MORE THAN THREE (3) BENDS, A PULL BOX OF SUITABLE SIZE SHALL BE PLACED IN A SUITABLE LOCATION TO MEET THE ABOVE CONDITIONS.

3. COORDINATE TELEPHONE AND DATA OUTLET LOCATIONS WITH OWNER. PROVIDE OUTLET BOX AND EMPTY RACEWAY WITH PULL WIRE IN INSULATED OR SOLID OR INACCESSIBLE AREAS. PROVIDE PLATES OF SAME MATERIAL AND FINISH AS SPECIFIED FOR RECEPTACLES. WALL PHONE PLATES SHALL HAVE MOUNTING STUDS.

### START UP AND INSTRUCTIONS

1. AFTER INSTALLATION, CHECK ALL EQUIPMENT, AND PERFORM START UP IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS. PLACE ALL SYSTEMS INTO OPERATION.

- 2. TESTS SHALL INCLUDE THE FOLLOWING:
  - o MEASURE THE LOAD ON